

Developing the Port of Seattle's Energy Portfolio

Final Recommendations

October 21, 2016

Table of Contents

- 1 Energy Committee Members
- 2 Project Objective & Approach
- 3 Energy & GHG Assessment & Load Growth Projections
- 4 Achieving the Century Agenda Goals
- 5 Summary of Energy Conservation & Renewable Energy Solutions
- 6 Findings & Recommendations
- 7 Detailed Descriptions of Conservation and Renewable Strategies

Energy Committee Members

| Name | Title | Department |
|----------------|---------------------------------|--|
| Andy Botts | Electrical Engineer | Aviation Facilities and Infrastructure |
| Terrance Darby | Sustainability Program Manager | Maritime Environment and Planning |
| Scott DeWees | Environmental Specialist | Aviation Environment and Planning |
| Stephanie Meyn | Climate Program Manager | Aviation Environment and Planning |
| Paul Meyer | Manager, Environmental Programs | Maritime Environment and Planning |
| Lynn Oliphant | Systems Engineer | Aviation Facilities and Infrastructure |
| Joseph Pelonio | Manager, Lease and Utilities | Portfolio Management (Corporate) |
| Leslie Stanton | Manager, Sustainability | Aviation Environment and Planning |
| Mike Tasker | Sr. Manager, Facilities | Aviation Facilities and Infrastructure |
| Wendell Umetsu | Manager, Electrical Systems | Aviation Facilities and Infrastructure |

Project Approach

Objective: Identify opportunities to achieve the Port of Seattle’s Century Agenda energy load growth and GHG reduction goals.

Task 1: Summarize Port-Wide Energy Use and GHG Projections

1. Sum Port-operated energy sources & uses
2. Estimate 20-year load growth and emission projections

Task 2: Strategy Identification and Exploration

1. Review energy strategies from peer organizations and private sector
2. Brainstorm with Port staff for additional opportunities
3. Screen list of opportunities

Task 3: Develop Energy Portfolio Recommendations

1. Estimate relative costs and impacts
2. Prioritize by Level of Confidence
3. Estimate impacts on Century Agenda goals
4. Develop final recommendations

Developing Port-Wide Energy Use and GHG Projections


- All electricity, natural gas, and liquid fuel bills paid by Port of Seattle were evaluated,
- All energy converted to MMBTU,
- Energy sub-metered and billed to tenants was not included in this evaluation,
- In many Port facilities, energy costs are recovered via flat fees, with no visibility into actual energy use,
- Future load growth was based on building model estimates completed for the Sustainable Airport Master Plan (SAMP).

Utility Bill Availability (does not include sub-metering)


| Airport | Included | |
|--|-------------|-------------|
| | Electricity | Natural Gas |
| Terminals/Cargo | ✓ | ✓ |
| Bus Maintenance Facility | ✓ | ✓ |
| Fire Station | ✓ | ✓ |
| Pumphouse | ✓ | ✓ |
| Distribution Center | ✓ | ✓ |
| Airfield & Perimeter Lighting | ✓ | N/A |
| Tenant Facilities (other than dining & retail) | ✓ | N/A |
| Generators (Liquid Fuels) | | ✓ |
| Fleet Vehicles (Liquid Fuels) | | ✓ |

| Seaport | Included | |
|-------------------------------|-------------|-------------|
| | Electricity | Natural Gas |
| Terminal 91 | ✓ | ✓ |
| Fisherman's | ✓ | ✓ |
| Shilshole Bay | ✓ | ✓ |
| Pier 66 | ✓ | ✓ |
| Pier 69 | ✓ | N/A |
| Marine Maintenance | ✓ | ✓ |
| MIC | ✓ | ✓ |
| Terminal 102 | ✓ | ✓ |
| Terminals 5 | ✓ | ✓ |
| Terminals 18, 102, & Parks | ✓ | ✓ |
| Fleet Vehicles (Liquid Fuels) | | ✓ |


Port-Wide Annual Energy Usage




Seaport Energy Use By Type 2011-2015




Airport Energy Use By Type 2011-2015




Port-Wide Annual Greenhouse Gas Emissions



Seaport GHG Tons By Source 2011-2015



Airport GHG Tons By Source 2011-2015



Port has a Strong Legacy of Energy Conservation

A Few Examples from Just the Last Three Years



Stage 2 Mechanical (2012-2014)

Energy Savings Estimate: 12,296 MMBTU/year



Escalator Upgrades and Replacement (2013)

Energy Savings Estimate: 1,568 MMBTU/year

Scope of work was 44 Escalators across the entire airport




Parking Garage LED & Emergency Lighting (2013 & 2015)


Energy Savings Estimate Emerg Lighting: 5,361 MMBTU/year

Energy Savings Estimate LED Lighting: 6,096 MMBTU/year


Port-wide Energy Forecast



Port-wide GHG Emissions Forecast



Task 2: Strategy Identification and Screening



Step 1: Identify Potential Strategies

We identified a range of conservation and renewable strategies currently undertaken by:

Port of Seattle

Peer Port Organizations

- Port of Amsterdam / Schiphol International Airport
- Port of Long Beach
- Port of Portland
- Port of Rotterdam
- Port of San Francisco / San Francisco International Airport
- Port of San Diego

Private Sector Entities

- Amazon
- Boeing
- Ikea
- GE
- Google
- Lockheed Martin
- Microsoft

Step 2: Screen By Impact & Feasibility


IMPACT

- Contribution toward load growth & GHG reduction goals
- Energy use reduction potential
- Renewable energy generation potential

FEASIBILITY

- Anticipated payback period
- Technical, physical, commercial availability
- Human factors & implementation difficulty

Step 2: Impact-Feasibility Results



High Impact:

- Achieves/helps with load growth goal
- Significant energy use reduction
- Significant renewable energy generation potentials

High Feasibility:






- Financial: >5 year payback
- Technical, physical, commercial availability
- Political: tenant reactions and human factors

Conservation





Renewables

Selected Strategy

Energy Conservation Strategies: Initial Screening






| Strategy | Impact? | Feasible? |
|--|---------|-----------|
|  <p>Advanced Building Envelope Systems</p> | High | High |
|  <p>Advanced Lighting Technologies & Controls</p> | High | High |
|  <p>Fleet Optimization</p> | Low | High |
|  <p>Hot Box Controls</p> | Low | High |
|  <p>Idle Reduction Programs</p> | Low | High |

Energy Conservation Strategies: Initial Screening




| Strategy | Impact? | Feasible? |
|--|---------|-----------|
|  Mechanical System Upgrades | High | High |
|  Metering & Data Acquisition System Upgrades | High* | High |
|  Plug Load Management | Low | High |
|  Building Retuning / Temperature Set Point Adjustments | Low | High |

*Metering does not reduce energy use but is a critical component of energy management that can directly lead to energy savings and aids in renewable energy deployment.

Renewable Energy Strategies: Initial Screening







| Strategy | Impact? | Feasible? |
|---|--|-----------|
|  | Emerging Generation Technologies | Unknown |
|  | Solar Photovoltaics | Low |
|  | Solar Supplement for Electric Vehicle Chargers | Low |
|  | Small Scale Wind | Low |
|  | Vehicle Electrification | Low |

Renewable Energy Strategies: Initial Screening

| Strategy | Impact? | Feasible? | |
|--|--|-----------|------|
|  A photograph showing an industrial facility with several large, rounded storage tanks and pipes, likely related to natural gas processing. | Renewable Natural Gas | High | High |
|  A photograph of a wind farm with several white wind turbines in a green field under a blue sky with clouds. | Power Purchase Agreement or Offsite Offset Project | High | High |
|  A photograph of industrial machinery, including pipes, valves, and a control panel, representing waste heat recovery equipment. | Waste Heat Recovery | Low | Med |

Energy Strategies

Removed from Further Consideration

| Strategy | Impact? | Feasible? | |
|---|--|-----------|-----|
|  | On-site Anaerobic Digestion of Organic Waste | Low | Low |
|  | Fuel Cells | Low | Low |
|  | Carbon Capture & Storage | High | Low |
|  | Cogeneration | High | Low |
|  | Geothermal | High | Low |
|  | Tidal Power | High | Low |

Prioritizing Energy Strategies by Level of Confidence

High

- Technical analysis complete
- Understand energy reduction potential
- Understand return on investment

Med

- Industry best practice
- Proven technology
- Understand potential benefits and costs at high level
- Further exploration warranted

Low

- Emerging technology
- Shows promise for potential application in Port context
- Many unknowns
- Further exploration warranted


Task 3: Recommended Energy Conservation Strategies

| Confidence | Conservation Measure | Key Components | Energy Use Reduction Potential (% Port Use) | Relative Cost per MMBTU Reduction | Relative Cost per CO2 Reduction |
|------------|--|---|---|-----------------------------------|---------------------------------|
| High | Metering & Data System Upgrades | <ul style="list-style-type: none"> Comprehensive metering and submetering of Port facilities Upgrades to SCADA (data acquisition) system | Enabling strategy | N/A | N/A |
| | Mechanical Upgrades | <ul style="list-style-type: none"> Includes metering, chiller sequencing, building envelope, pump optimization, data center & other upgrades | 2% | Med | Med |
| Med | Advanced Lighting Technologies & Controls | <ul style="list-style-type: none"> Emerging lighting technologies such as plasma lighting Lighting controls (automation) & policy measures | 5% | Low | Med |
| | Plug Load Management | <ul style="list-style-type: none"> Schedule-based timing controls to automate power supply to plug-load equipment such as electronics | 1% | Low | Med |
| | Building Retuning | <ul style="list-style-type: none"> Temperature setpoint adjustments & policy Diagnosis and correction of building systems operations & controls | 2% | Low | Low |
| | Fleet Optimization | <ul style="list-style-type: none"> Replacement of diesel and gasoline powered vehicles with electric equivalents | 1% | TBD | TBD |
| Low | Advanced Building Envelope Systems | <ul style="list-style-type: none"> Daylighting Adaptive envelope systems such as “electrochromic” (self-tinting) glass | 3% | Med | Med |


Task 3: Recommended Renewable Energy Strategies

| Confidence | Renewable Energy Measure | Description | Energy Generation Potential (% Port Use) | Relative Cost per MMBTU Reduction | Relative Cost per CO2 Reduction |
|------------|---|---|--|-----------------------------------|---------------------------------|
| High | Renewable Natural Gas (RNG) | <ul style="list-style-type: none"> Source RNG from landfills, wastewater treatment, or agricultural sources | 35% | Med | Med |
| | Solar Photovoltaics | <ul style="list-style-type: none"> Install solar panels on existing terminal, garage, and cargo areas, and future expansion facilities | 1% | Med | High |
| Med | Power Purchase Agreement or Offsite Offset Project | <ul style="list-style-type: none"> Purchase wind or solar energy directly from third-party owned and operated renewable energy generation facility, on or off Port property | TBD | Med | Med |
| Low | Emerging Generation Technologies | <ul style="list-style-type: none"> Microhydroelectric generators that power from harvested rainwater flows Kinetic tiles that generate power from vibrations such as foot and vehicle traffic | TBD | TBD | TBD |

Task 3: Impact of Strategies on Century Agenda Goal for Energy



Task 3: Impact of Energy Strategies on Century Agenda Goal for GHG Emissions



Key Findings

The Port's energy demand and GHG emissions have remained constant over the past 5 years. However, our forecast show **if we do nothing, our energy will increase by 46% and GHGs by 59%**, respectively, over the next 25 years due to airport expansion.

The Committee finds that the **Port will be able to meet the Century Agenda energy and GHG goals through a combination of efficiency and renewable fuel strategies, even in light of the projected growth in demand.**

According to our analysis, energy conservation strategies can meet about **25% of the projected increase** in energy demand.

The remaining **75% of our increased energy demand** must be met with renewable fuels.

Renewable Natural Gas is an essential component to our strategy, both in terms of energy load growth and GHG reductions, but is a high-risk strategy.

Solar offers limited reductions to both energy and GHG projections, but may have other sustainability benefits.

Key Findings Cont'd

Much of existing metering infrastructure is outdated and inconsistent.

Low-cost conservation opportunities remain, but cannot achieve our goals alone.

Payback thresholds for higher cost energy conservation investments are not aligned with long term goals.


Our energy demand forecasts assume future facilities are built to highest green standards, including going beyond current energy efficiency standards.

The Committee opted not to include Port electricity used for electric GSE and PC air, because increased load growth is minimal when compared to resulting GHG reductions (see following slide).

Tenant energy use is significant, but metering infrastructure is inconsistent and in some cases entirely lacking.

Case In Point: Airport Gate Electrification

- Every gate at the Airport is equipped with remote ground power connections and pre-conditioned air supplied from a central plant
- Aircraft parked at gates use power and conditioned air provided by the Airport instead of their Auxiliary Power Units, which run on jet-fuel
- While Port-owned emissions increase slightly, the resulting overall emission reductions are significant



Final Recommendations

- ▶ Pursue RNG opportunities as a critical element of our energy and GHG strategy, with second phase to coincide with Airport expansion
- ▶ Align payback thresholds for energy investments (both O&M and capital) with the planning horizons for the Century Agenda and Airport Master Plan, and ensure life cycle costs and nonfinancial benefits are considered
- ▶ Ensure future facilities are built to highest green standard; building to a lower standard will increase our load growth
- ▶ Continued focus on conservation, such as through the Stage 3 Mechanical Conservation Project, will reduce our reliance on hydroelectricity and will free up clean energy capacity for other uses
- ▶ Enhanced metering will assist in prioritization of energy conservation opportunities for both Port and tenants
- ▶ Establish a strategy for emerging technologies to better evaluate viability for Port adoption

Appendix: Background Data for Energy Strategies

| Conservation Measure | Metering & Data Acquisition System Upgrades |
|--|--|
| Key Components | <ul style="list-style-type: none">• Comprehensive metering and submetering of Port facilities to enable measurement & verification of energy conservation strategies• Upgrades to SCADA (data acquisition) system |
| Energy Use Reduction Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• Does not lead to direct energy savings, but is necessary to enable participation in a wide range of industry best practices such as load curtailment, demand response, and measurement and verification of conservation programs.• Will assist in prioritization of energy conservation opportunities for both Port and tenants. |
| Port-Specific Supporting Analysis | <ul style="list-style-type: none">• Current state and needs relative to metering and submetering are documented in the Sustainable Airport Master Plan (Section 6.12), the Cardno Report (Section 5), and Phase 3 University Mechanical Energy Conservation presentation.• Each of these documents presents recommendations for enhanced metering and submetering. |
| Feasibility Constraints | <ul style="list-style-type: none">• Scale of implementation required to achieve desired technical consistency may be prohibitive |
| Recommendations | <ul style="list-style-type: none">• Enhanced metering capabilities will allow the Port to recover its fair share for utility costs incurred by tenants, which are currently underrepresented through existing metering infrastructure.• This opportunity cost should be factored in payback analysis for this measure.• Explore partnership opportunities with BPA and SCL to support advanced metering technologies |

Appendix: Background Data for Energy Strategies

| Conservation Measure | Mechanical Upgrades |
|--|---|
| Key Components | <ul style="list-style-type: none">• Includes metering, chiller sequencing, building envelope upgrades, pump optimization, data center & other upgrades |
| Energy Use Reduction Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• 20,449 MMBTU reduction in Port energy use• 2% reduction in Port energy use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• Internal Airport reports indicate electricity can be reduced by 2,017 MMBTU and natural gas can be reduced by 18,432 MMBTU |
| Cost Information | <ul style="list-style-type: none">• \$4.95M (see Option 2 of Stage 3 Mechanical Energy Conservation Presentation)• \$242 / MMBTU, \$4,994 / metric ton of CO₂• Port is eligible for rebates and incentives by BPA and SCL to offset cost of lighting upgrades and other energy efficiency projects |
| Port-Specific Supporting Analysis | <ul style="list-style-type: none">• Mechanical Energy Conservation Stage 1-3 Reports |
| Feasibility Constraints | <ul style="list-style-type: none">• Simple payback terms do not appear to be competitive on basis of energy efficiency alone, but some mechanical equipment past useful life |
| Recommendations | <ul style="list-style-type: none">• Pursue Stage 3 Mechanical Energy Conservation project• Continue to identify equipment replacement opportunities |

Appendix: Background Data for Energy Strategies

| Conservation Measure | Advanced Lighting Technologies & Controls |
|--|--|
| Key Components | <ul style="list-style-type: none"> Emerging lighting technologies such as plasma lighting Lighting controls (automation) & policy measures |
| Energy Use Reduction Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none"> 45,368 MMBTU reduction in Port energy use 4% reduction in Port energy use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none"> Facilities team estimates this initiative can reduce the lighting load by 20% at the Airport and 10% at the Seaport Lighting load was assumed to be 50% of total 2014 electricity |
| Cost Information | <ul style="list-style-type: none"> Port is eligible for rebates and incentives by BPA and SCL to offset cost of lighting upgrades and other energy efficiency projects |
| Case Study Examples & Best Practice Data | <ul style="list-style-type: none"> Berkeley National Lab Meta-Analysis of Energy Savings From Lighting Controls in Commercial Buildings California Energy Commission, Achieving Energy Efficient Lighting in California, 2015 |
| Feasibility Constraints | <ul style="list-style-type: none"> Technologies continue to evolve Many of Port's operations are 24/7, and many spaces are tenant controlled or directly impact tenants |
| Recommendations | <ul style="list-style-type: none"> Institute lighting controls and policy measures in administrative areas Explore opportunities for lighting controls in public spaces during off-peak periods Identify funding to continue LED retrofits and lighting control projects Continue to track developments in emerging technologies such as plasma lighting |

Appendix: Background Data for Energy Strategies

| Conservation Measure | Plug Load Management |
|--|--|
| Key Components | <ul style="list-style-type: none">• Schedule-based timing controls to automate power supply to plug-load equipment such as electronics |
| Energy Use Reduction Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• 1,762 MMBTU reduction in Port energy use• 1% reduction in Port energy use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• Facilities team estimates this initiative can reduce the plug load by 5% at the Airport• The plug load was assumed to be 8% of total electricity |
| Cost Information | <ul style="list-style-type: none">• Most plug load strategies are no or low cost |
| Case Study Examples & Best Practice Data | <ul style="list-style-type: none">• GSA Public Building Service: Plug Load Control• National Renewable Energy Laboratory: Assessing and Reducing Plug and Process Loads in Office Buildings• New Buildings Institute: Plug Load Best Practices Guide |
| Feasibility Constraints | <ul style="list-style-type: none">• Many of Port's operations are 24/7, and many spaces are tenant controlled or directly impact tenants• Growth planned to provide increased access to electronics charging for Airport passengers |
| Recommendations | <ul style="list-style-type: none">• Institute plug management program in administrative areas• Explore opportunities for plug load management in public spaces during off-peak periods |

Appendix: Background Data for Energy Strategies

| Conservation Measure | Building Retuning |
|--|---|
| Key Components | <ul style="list-style-type: none"> • Temperature setpoint adjustments & policy • Diagnosis and correction of operational problems with building systems and their controls |
| Energy Use Reduction Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none"> • 18,901 MMBTU reduction in Port energy use • 2% reduction in Port energy use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none"> • Facilities team estimates this initiative can reduce electrical HVAC use by 5%, and natural gas HVAC use by 15% • HVAC load is assumed to be 21% of total electricity and 23% of total natural gas |
| Cost Information | <ul style="list-style-type: none"> • Airport has budgeted \$100,000 per year for this type of work which equates to: • \$5 / MMBTU, \$136 / metric ton of CO₂ • Some building retuning measures may be eligible for rebates and incentives from BPA and SCL |
| Case Study Examples & Best Practice Data | <ul style="list-style-type: none"> • US Department of Energy: Energy Savings Modeling of Standard Commercial Building Retuning Measures: Large Office Buildings |
| Feasibility Constraints | <ul style="list-style-type: none"> • Policy measure is needed in order to ensure sustainability/acceptance of temperature setpoint changes |
| Recommendations | <ul style="list-style-type: none"> • Pursue temperature setpoint adjustments as soon as practicable • Continue pursuit of retro-commissioning measures |

Appendix: Background Data for Energy Strategies

| Conservation Measure | Fleet Optimization & Electrification |
|--|--|
| Key Components | <ul style="list-style-type: none">• Replacement of diesel and gasoline powered vehicles with electric equivalents |
| Energy Use Reduction Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• 4,735 MMBTU Potential Reduction• 1% of total Port Energy Use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• Discussions have indicated that a 15% reduction in MMBTU use from diesel and gasoline powered vehicles is possible with fuel efficiency and additional electric vehicles |
| Cost Information | <ul style="list-style-type: none">• TBD |
| Case Study Examples & Best Practice Data | |
| Feasibility Constraints | <ul style="list-style-type: none">• Operational considerations of specific vehicle types may be a concern for some staff |
| Recommendations | <ul style="list-style-type: none">• Continue to pursue fleet optimization activities Port-wide |

Appendix: Background Data for Energy Strategies

| Conservation Measure | Advanced Building Envelope Systems |
|--|---|
| Key Components | <ul style="list-style-type: none">• Daylighting• Adaptive envelope systems such as “electrochromic” (self-tinting) glass |
| Energy Use Reduction Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• 27,521 MMBTU reduction in Port energy use• 2% reduction in Port energy use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• Facilities team estimates this initiative can reduce total electric load by 5% |
| Cost Information | |
| Case Study Examples & Best Practice Data | |
| Feasibility Constraints | <ul style="list-style-type: none">• Glint and glare considerations may be important for particular solar glass technologies |
| Recommendations | <ul style="list-style-type: none">• As new facilities come online, evaluate potential for incorporation of electrochromic glass and other advanced envelope technologies• Ensure energy payback evaluations are taken into account |

Appendix: Background Data for Energy Strategies

| Renewable Measure | Renewable Natural Gas (RNG) |
|---|---|
| Key Components | <ul style="list-style-type: none">• Source RNG from landfills, wastewater treatment, or agricultural sources |
| Energy Generation Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• 350,000 MMBTU Potential Reduction• 30% of total Port Energy Use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• Based on most recent discussions, local biogas production facility indicates they can steadily supply 350,000 MMBTU of renewable natural gas to the Airport |
| Port-Specific Supporting Analysis | <ul style="list-style-type: none">• Airport has conducted multiple in-house explorations of RNG deals• 2 landfill operators have provided potential costs |
| Cost Data | <ul style="list-style-type: none">• \$7.50-\$14/MMBTU• \$100-\$200/tonne CO2 |
| Feasibility Constraints | <ul style="list-style-type: none">• Pipeline and infrastructure costs are potentially prohibitive |
| Recommendations | <ul style="list-style-type: none">• Pursue RNG opportunities as a critical element of our energy & GHG strategy, with second phase to coincide with Airport expansion |

Appendix: Background Data for Energy Strategies

| Renewable Measure | Solar Photovoltaics |
|--|---|
| Key Components | <ul style="list-style-type: none"> • Install solar panels on existing terminal, garage, and cargo areas, and future expansion facilities, either through power purchase agreement or Port-owned project |
| Energy Generation Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none"> • 1,922 MMBTU Potential Reduction • 1% of total Port Energy Use |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none"> • Solar PV panels at the Airport's T2 expansion and at the Seaport are assumed to generate 1,917 MMBTU and 5 MMBTU respectively |
| Cost Data | <ul style="list-style-type: none"> • \$1,000 / MMBTU, \$144,000 / tonne CO₂ |
| Port-Specific Supporting Analysis | <ul style="list-style-type: none"> • SAMP Task 6.12 includes an evaluation of the solar generation potential using a RETScreen V4 simulation for existing and proposed expansion roof areas. The simulation used modern PV panels in Seattle, based on the optimal installation angle. The analysis assumes a roof available area of 65% for terminals and 90% available for the garage (assuming solar canopies). |
| Case Study Examples, Best Practice Data, and Other Resources | <ul style="list-style-type: none"> • Airport Cooperative Research Program (ACRP) Report 108: Guidebook for Energy Facilities Compatibility with Airports and Airspace • Port of San Francisco, Unified Port of San Diego, San Diego International Airport, Port of Amsterdam, Schiphol International Airport |
| Feasibility Constraints | <ul style="list-style-type: none"> • The amount of power generated by installing PV on both existing and future facilities would only power a fraction of the Port's electrical requirements • See FAA Technical Guidance for Evaluating Selected Solar Technologies on Airports |
| Recommendations | <ul style="list-style-type: none"> • Pursue smaller-scale PV installations on existing and new facilities as opportunities emerge |

Appendix: Background Data for Energy Strategies

| Renewable Measure | Power Purchase Agreement or Offsite Offset Project |
|---|---|
| Key Components | <ul style="list-style-type: none">• Purchase wind or solar energy directly from third-party owned and operated renewable energy generation facility, on or off Port property |
| Energy Generation Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• Scalable as needed |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• Assumes Eastern Washington site |
| Cost Data | <ul style="list-style-type: none">• \$144,000 / metric ton of CO₂• \$45M wind farm = 1,248 tonnes CO₂ |
| Port-Specific Supporting Analysis | <ul style="list-style-type: none">• Airport has conducted in-house evaluation of offset projects |
| Case Study Examples, Best Practice Data, and Other Resources | <ul style="list-style-type: none">• Google's Green PPAs• Multiple airport projects, including Denver International Airport, Indianapolis International Airport, Port of Portland |
| Feasibility Constraints | <ul style="list-style-type: none">• Consider reviewing revenue diversion issues |
| Recommendations | <ul style="list-style-type: none">• RECs can easily offset any shortfalls in goal achievement |

Appendix: Background Data for Energy Strategies

| Renewable Measure | Onsite Micro-Hydroelectric Power |
|---|--|
| Key Components | <ul style="list-style-type: none">• Emerging technology that produces power from harvested rainwater flows• Potential for smaller scale, passenger-facing, public-private demonstration program |
| Energy Generation Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• TBD |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• TBD |
| Port-Specific Supporting Analysis | <ul style="list-style-type: none">• N/A |
| Case Study Examples, Best Practice Data, and Other Resources | <ul style="list-style-type: none">• N/A |
| Feasibility Constraints | <ul style="list-style-type: none">• TBD |
| Recommendations | <ul style="list-style-type: none">• Continue to track development of this technology for potential application |

Appendix: Background Data for Energy Strategies

| Renewable Measure | Kinetic Generators |
|---|--|
| Key Components | <ul style="list-style-type: none">• Emerging technology that produces power from vibrations such as foot and vehicle traffic• Potential for smaller scale, passenger-facing, public-private demonstration program |
| Energy Generation Potential (MMBTU and % of total Port Energy Use) | <ul style="list-style-type: none">• TBD |
| Energy Use Reduction Potential - Assumptions | <ul style="list-style-type: none">• TBD |
| Port-Specific Supporting Analysis | <ul style="list-style-type: none">• N/A |
| Case Study Examples, Best Practice Data, and Other Resources | <ul style="list-style-type: none">• N/A |
| Feasibility Constraints | <ul style="list-style-type: none">• TBD |
| Recommendations | <ul style="list-style-type: none">• Continue to track development of this technology for potential application |