

This document is a text-only reovery of the original PDF file. Any graphics that were in the original PDF are not included here. If you need the original document, please contact the Commission Clerk at the Port of Seattle.

Item No. 8e_supp
Meeting Date: August 9th, 2022
Procurement
Chiller 6 Repairs

Chiller 6 Controls Tubes
Capacity: 1500 Tons Controls to be All tubes must be
1 of 8 Chillers in CMP upgraded as part of removed to provide
F&I project. access to ruptured
Supplies 10% of SEA
ones.

Procurement Item No. 8e_supp
Meeting Date: August 9th, 2022
Chiller 6 Repairs

Flow Control Ruptured Tube Looking East
Controls flow between Internal tubes froze Unbolted cover of
terminal and cooling and ruptured. These Chiller 6.
towers. must be replaced.

2